

TECHNICAL SPECIFICATION FOR THE PUBLIC BIDDING OF:

**UPLB-S-060-8-17, SUPPLY AND DELIVERY OF WINDOW TYPE AIRCONDITIONING UNITS**

DATE OF PRE-BID CONFERENCE:

**Wednesday, 2 August 2017 3:00 PM**

DEADLINE OF SUBMISSION OF BIDS:

**Wednesday, 16 August 2017 UNTIL 1:15 PM**

OPENING OF BIDS:

**Will follow shortly after the deadline of the submission of bids**

LOT #	ITEM #	REQUIRED SECIFICATIONS	OFFERED SPECIFICATIONS (write down detailed offered specifications)	REFERENCES (include supporting documents)	COMMENTS/ REMARKS (clarify inclusion/ exclusion)	EVALUATION
<b>1</b>	<b>1</b>	<b>Suppy and Delivery of Branded and Brand New Window Type Airconditioning unit</b>				
		2HP, Inverter				
		Voltage = 220VAC				
		60Hz, EER-minimum 10,				
		cooling capacity = atleast 18,600kj/h,				
		Warranty: one year on parts and services and five years on compressor				
		Delivery: 30 CD upon receipt of Notice to Proceed				
<b>2</b>		<b>Suppy and Delivery of Branded and Brand New Window Type Airconditioning unit</b>				
		2.0 HP inverter window type room airconditioning,				
		volt 230 hz60. 1 phase KJ/hr				
		EER11.7 amps				
		min. DC inverter 7 60 Watts 626-1570 wireless remote control R420A				
		Warranty: one year on parts and services and five years on compressor				
		Delivery: 30 CD upon receipt of Notice to Proceed				

Note: Please fill-up applicable columns.

Signature of Representative: \_\_\_\_\_

Name of Representative: \_\_\_\_\_

Position: \_\_\_\_\_

Company: \_\_\_\_\_

Address: \_\_\_\_\_

Telephone/ Fax: \_\_\_\_\_

Email: \_\_\_\_\_

End-user:

\_\_\_\_\_  
 Signature over Printed Name