

TECHNICAL SPECIFICATION FOR THE PUBLIC BIDDING OF:

UPLB-S-060-8-17, SUPPLY AND DELIVERY OF WINDOW TYPE AIRCONDITIONING UNITS (REVISED)

DATE OF PRE-BID CONFERENCE:

Wednesday, 2 August 2017 3:00 PM

DEADLINE OF SUBMISSION OF BIDS:

Wednesday, 16 August 2017 UNTIL 1:15 PM

OPENING OF BIDS:

Will follow shortly after the deadline of the submission of bids

LOT #	ITEM #	REQUIRED SECIFICATIONS	OFFERED SPECIFICATIONS (write down detailed offered specifications)	REFERENCES (include supporting documents)	COMMENTS/ REMARKS (clarify inclusion/ exclusion)	EVALUATION
1	1	Supply and Delivery of Branded and Brand New Window Type Airconditioning unit				
		2HP, DC Inverter				
		Voltage = 220VAC				
		60Hz, EER-minimum 10,				
		cooling capacity = atleast 18,600kj/h,				
		Warranty: one year on parts and services and five years on compressor				
		Delivery: 30 CD upon receipt of Notice to Proceed				
		remote control				
2		Supply and Delivery of Branded and Brand New Window Type Airconditioning unit				
		2.0 HP inverter window type room airconditioning,				
		volt 230 hz60. 1 phase				
		COOLING CAPACITY AT LEAST 18,600KJ/hr				
		EER11.7				
		min. DC inverter 7 60 Watts 626-1570 wireless remote control				
		Warranty: one year on parts and services and five years on compressor				
		Delivery: 30 CD upon receipt of Notice to Proceed				

Note: Please fill-up applicable columns.

End-user:

 Signature over Printed Name

Signature of Representative: _____

Name of Representative: _____

Position: _____

Company: _____

Address: _____

Telephone/ Fax: _____

Email: _____