



PROJECT

TIME	BIDDING NO.	PROJECT TITLE	ABC (PhP)	END-USER
1:30 PM	IF-004-17 REBID	SUPPLY AND INSTALLATION OF OVERHEAD AND SECONDARY ELECTRICAL LINE, BIOTECH COMPLEX, UPLB REBID	1,563,034.49	BIOTECH, OVCRE

SUBJECT : **Bid Bulletin No. 2**

Date : **06 Sept 2017**

To : **All Concerned Eligible Bidders**

This **BID BULLETIN NO. 2** is hereby issued for your information and guidance in connection with the above-mentioned bidding.

Clarification on the queries of Azulrem Construction & Engineering Services regarding the abovementioned project:

- **Query # 1** (Kilowatt – Hour Meter, V 66 – S Class 200, 3 ϕ , Delta 4 Wires, 240 V, with Socket Base, Proposed Equivalent: GE KV – 2C Form 9S, 240V with Base, 3 ϕ
*Reason: G2 V66 – S is obsolete and GE has since then, stopped commercial production of this model.
You may, however, suggest other options.)*

The prospective bidder shall submit the proposed equivalent material without additional cost. These are the following specifications:

*Polyphase Meter. Type GE KV2C form 48a
Class 20, (120-480V) 3WD or HWY, complete
with TOU Battery, KVAR, KVA, Power Factor
and Load Profile functions, ERC Sealed,
Brand New.*

Hoping this will satisfactorily answer the clarifications of the prospective bidder.

This **BID BULLETIN NO. 2** shall form an integral part of the bid documents for this public bidding.


ROSSANA MARIE C. AMONGO, PhD
Chair, BAC