



UNIVERSITY OF THE PHILIPPINES
LOS BANOS
Los Banos, IV-A
VAT Reg. TIN: 000-864-006-00004

UPLB BAC SECRETARIAT
BY: [Signature] DATE: 4/26/21
MAY 03 2021 -TIL 10AM
UPLB-RQ- A-018-21-I
DEADLINE OF SUBMISSION

Request for Quotation/ Bid Form (Technical Specifications)
Socio-Economics Research and Data Analytical Laboratory: Commodity-Specific Data Analytics and Capacity Building Support to Socio-economics R&D (SERDAL)

UPLB-RQ-

DEADLINE OF SUBMISSION:

Suppliers Name: _____

Date _____
Fund Code: N9-146-3A
MOP: _____
Contact No: 9062196432
Contact Person: Sharmaine Marasigan

- Bidders shall provide correct and accurate information required in this form. All entries must be typewritten or in print and properly accomplished. Do not leave blank entries, put N/A for not applicable.
- Price quotation/s to be denominated in Philippine Peso shall include all taxes, duties, and/ or levies payable.
- Bidders must indicate the BRAND and MODEL NUMBER for equipment and its accessories or peripherals. Evidence shall be in the form of manufacturer's un-amended sale literature, unconditional statement of specification and compliance issued by
- Quotation through fax/email is acceptable. Winning bidder shall submit original signed RQ before issuance of Purchase order (P.O.).
- Quotations exceeding the Approved Budget for Contract shall be rejected.
- Documentary requirements per Memorandum No. 03 Series of 2017 shall be attached upon submission of the quotation
- Others: _____

GENERAL NAME OF THE ITEM	REQUIRED SPECIFICATIONS	UNIT OF MEASURE	QUANTITY	ESTIMATED UNIT APPROVED BUDGET OF THE CONTRACT	ESTIMATED TOTAL APPROVED BUDGET OF THE CONTRACT	OFFERED SPECIFICATION Suppliers must state here the detailed technical specifications of their	QUOTED UNIT PRICE	TOTAL QUOTED PRICE	EVALUATION (Leave this space blank. For BAC/ Evaluators only)
Airconditioning Unit	Branded and Brand new <i>(supply, delivery & installation)</i>	lot	1.00	201,039.05	201,039.05				
	3.0 TR FULL DC Inverter type Ceiling Cassette Split Type Airconditioning Unit								
	Rated Cooling Capacity: 12,500-38,400KJ/hr,								
	Power Input: 685-3,550								
	Watts, 10.8-18.2 EER								
	Power Supply: 230 Volts								
	1 Phase 60Hz., Current 16 Amps								
	Refrigerant(R410A)								
	Wireless Remote Control								
	Attached Certificate of Warranty								
	A) Provision. Finished pad foundation with steel frame as per drawing								
	B) Layout and installation of fabricated angle bar 3/16" x 1 1/2" thickness, pre-painted primer epoxy (gray) for FCU and ACCU								
	C) Chipping and Plastering								
	D) Mounting and installation of Air conditioning unit FCU and ACCU with Rubber Pad Support								

	E) Layout and Installation of drainage pipeline using PVC 3/4" Diameter (Elson Blue) with rubber hose insulation							
	F) Layout and installation of drainage pipeline using PVC (Neltex) including power and transmission wirings from FCU to ACCU using 3.5mm ² including grounding line							
	G) Layout and termination of electrical Wiring 5.5mm ² with PVC (Neltex) from ACCU to 50 amp. Circuit breaker NEMA 3r Enclosure (1-2 meters from ACCU)							
	H) Layout and Installation of hard drawn copper pipe 5/8" O.D and 3/8" O.D Type-L with rubber insulation 3/4" thickness from FCU to ACCU including Vinyl tape insulation							
	I) Leak testing and correction, System flushing and vacuuming							
	J) Provision/Metal Cladding of refrigerant pipe sets, from ACCU to FCU, using Galvanize Iron Gauge 0.5mm, as per drawing 1"x3"x4" Bending sizes Pre-painted (same as wall painted)							
see attached list of materials to be supplied and to be used for the installation of branded and brand new 3.0 TR Full DC inverter type ceiling cassette split type AC unit	K) Refrigerant Charging and start up with commissioning							
	L) Attach of certificate warranty							
				TOTAL ABC	201,039.05			
						TOTAL QUOTED AMOUNT IN WORDS:		

Reviewed and Checked By:

Jon Nell L. Bernardo
BAC TWG

Sharmaine Marasigan

TERMS AND CONDITIONS:

1. Price quotation/s shall be valid for a period of at least (30) calendar days from the date of submission.
2. In order to assure that manufacturing defects shall be corrected by supplier, a warranty security shall be required from the contract awardee for a minimum period of **three (3) months**, in the case of EXPENDABLE SUPPLIES, or a **minimum of one (1)**
3. Delivery period within _____ calendar days.
4. Award of contract shall be made to the lowest quotation which complies with the technical specifications, and other terms and condition stated herein
5. UPLB reserves the right to reject any or all offers as may be considered most advantageous to the University.
6. Any interlineations, erasure, or overwriting shall be valid only if they are signed or initiated by you or any of your duly authorized representative/s.

Requirements for Suppliers (GPPB Resolution No. 21-2017)

REQUIREMENTS	Shopping	Negotiated	Negotiated	Negotiated	Negotiated
Mayor's/Business Permit	/	/	/	/	/
PhilGEPS Registration Number	/	/	/	/	/
Professional license/ CV (consulting services)		/		/	
PCAB License (for Infrastructure)		/			
Income / Business tax returns (except for government agencies as lessor)		FOR ABC'S ABOVE	/	/	FOR ABC'S ABOVE
Omnibus Sworn Statement		FOR ABC'S ABOVE			FOR ABC'S ABOVE
NFCC for Infrastructure with ABC above Ph500k		/			FOR ABC'S ABOVE

Tel. No. : _____
Fax No. : _____
Email Address: _____

Date: