

## UNIVERSITY OF THE PHILIPPINES LOS BANOS Los Banos, IV-A VAT Reg. TIN: 000-884-006-00004

Request for Quotation/ Bid Form (Technical Specifications)
TYPE END USER/DEPARTMENT UNIT: INSTITUTE OF PLANT BREEDING

UPLB BAC SECRETARIAT BY: DATE: 7/61/2 JUL 1 2 2021

UPLB-RQ- 7-037-21-1- Dam UPLB-RODEADLNE OF SUBMISSION

DEADLINE OF

•	Date	May 19, 2021	
Suppliers Name:	Fund Code:		_
	MOP:	N91832B	
	Contact No:	9173924138	
	Contact Person	ROWENA FRANKIE	

## Please quote your lowest price on the item/s listed below, subject to the General Conditions below. With PCAB License Note

1. Bidders shall provide correct and accurate information required in this form. All entries must be typewritten or in print and properly accomplished. Do not 2. Price auotation/s to be denominated in Philipoine Peso shall include all taxes, duties, and/or levies pavable.

3. Bidders must indicate the BRAND and MODEL NUMBER for equipment and its accessories or peripherals. Evidence shall be in the form of manufacturer's 4. Quotation through fax/email is acceptable. Winning bidder shall submit original signed RQ before issuance of Puchase order (P.O.).

5. Quotations exceeding the Appoved Budget for Contract shall be rejected.

6. Documentary requirements per Memorandum No. 03 Series of 2017 shall be attached upon submission of the quotation

7. Others:

Agricanditionia 2 negrigepotion
Warks

ITEM No.	GENERAL NAME OF THE ITEM	REQUIRED SPECIFICATIONS	UNIT OF MEASURE	QTY	ESTIMATED UNIT APPROVED BUDGET OF THE CONTRACT	ESTIMATED TOTAL APPROVED BUDGET OF THE CONTRACT	OFFERED SPECIFICATION Suppliers must state here the detailed technical specifications of their offer against each of the individual parameters of each requirements	QUOTED UNIT PRICE	TOTAL QUOTED PRICE	EVALUATION (Leave this space blank, For BAC/ Evaluators only)
1	Aircon	Brand New 1.5 HPFULL DC Inverter Type Wall Mounted Split Type Air-Conditioning Unit with Rated Cooling Capacity (minmax) 11,020 (3, 310-13, 680) Kj/h, 14.69 EER, Power Input 750 (260-1, 170), Watts, Power Source 230 Volts, 1-Phase, 60Hz, Current 3.4 Amps, Refrigerant R-32, Wireless Remote Control, 1 Year Warranty	Set	1	51,600.00	51,600.00				
2	Supply, Labor and Materials	A,) Layout and Installation of Fabricated Angle Bar 3/16"x 1 1/2"Thickness, Pre- Painted Primer Epoxy (Gray) for ACCU								
		B.) Mounting and Installation of Air- Conditioning Unit FCU and ACCU with Rubber Pad Support								
		C.) Chipping and Plastering								
		D.) Layout and Installation of Drainage Pipeline using PVC 1/2"Diameter (Eslon Blue)			4-00-					
		E.) Layout and Installation of Electrical Connection for Power and Transmission Wirings from FCU to ACCU using 3.5mm <sup>2</sup> Including Grounding Line								

G.) Layout and Installation of Hard Drawn Copper Pipe 1/2" O.D. and 1/4"O.D. Type-L with Rubber Insulation 3/4"Thickness from FCU to ACCU including Vinyl Tape Insulation H.) Leak Testing and Correction, System Flushing and Vaccuming I.) Provision/Metal Cladding of Refrigerant Pipe Sets, from ACCU to FCU, using Galvanize Iron Gauge O.5mm, as per drawing 1"x3"x4"Bending Sizes Pre-Painted (same as Wall Painted) J.) Refrigerant Charging and Start Up with Commissioning K.) Attach Certificate of Warranty	F.) Layout and Installation of Electrical Wiring 5.5mm <sup>2</sup> with PVC (Neltex) from ACCU to 30 Amps. Circuit Breaker NEMA 3R Enclosure (1 meter from ACCU)	Set	1	26,883.90	26,883.90		
Correction, System Flushing and Vaccuming  I.) Provision/Metal Cladding of Refrigerant Pipe Sets, from ACCU to FCU, using Galvanize Iron Gauge 0.5mm, as per drawing 1"x3"x4"Bending Sizes Pre-Painted (same as Wall Painted)  J.) Refrigerant Charging and Start Up with Commissioning  K.) Attach Certificate of	of Hard Drawn Copper Pipe 1/2" O.D. and 1/4"O.D. Type-L with Rubber Insulation 3/4"Thickness from FCU to ACCU including						
of Refrigerant Pipe Sets, from ACCU to FCU, using Galvanize Iron Gauge 0.5mm, as per drawing 1"x3"x4"Bending Sizes Pre- Painted (same as Wall Painted)  J.) Refrigerant Charging and Start Up with Commissioning K.) Attach Certificate of	Correction, System Flushing						
Start Up with Commissioning K.) Attach Certificate of	of Refrigerant Pipe Sets, from ACCU to FCU, using Galvanize Iron Gauge 0.5mm, as per drawing 1"x3"x4"Bending Sizes Pre- Painted (same as Wall						
	Start Up with Commissioning						

Reviewed	and Check	ed By		_
ENG.	ION	RIELL	L. BE	RNARDO
	711	BAC TV	NG	

Please quote at your government price (including VAT) and state that the time within which you can make follow. It will be appreciated if we LOURDESID. TAYLO

BUYER/ END-USER

TEDUS	AND	CONDITIONS.

. .

TEDBLE AND CONDITIONS
1. Price quotation/s shall be valid for a period of at least (30) calendar days from the date of submission.

2. In order to assure that manufacturing defects shall be corrected by supplier, a warranty security shall be required from the contract awardee for a minimum period of three

3. Delivery period within \_\_\_\_\_\_ calendar days.

4. Award of contract shall be made to the lowest quotation wich complies with the technical specifications, and other terms and condition stated herein

5. UPLB reserves the right to reject any or all offers as may be considered most advantageous to the University.

6. Any interlineations, erasure, or overwriting shall be valid only if they are signed or initiated by you or any of your duly authorized representative/s.

Requirements for Suppliers (GPPB Resolution No. 21-2017)
REQUIREMENTS Negotiated Procurement-Small Value Shopping (Section 52) Negotiated Procurement-Negotiated Negotiated Procurement-Scientific, Scholarly Procurement-Lease of Real Emergency (Section 53.2) or Artistic Work, Exclusive Technology and Media Services (Section 53.6) Property or Venue (Section 53.10) (Section 53.9)

 Mayor's/Business Permit
 PhilGEPS Registration Number
 Professional license/ CV (consulting services)
 PCAB License (for Infrastructure)
 Income / Business tax returns (except for government agencies as lessor)
 Omnibus Sworn Statement FOR ABC'S ABOVE 500K FOR ABC'S FOR ABC'S ABOVE 50K FOR ABC'S ABOVE 50H ABOVE 500K 7 NFCC for Infrastructure with ABC above Ph500k

After having carefully read and accepted your General Conditions, I/We quote you on the Item at prices noted above.

Name of the Company:

Tel. No.: Tel. No. : Fax No. : Email Address: Date: Signature over Printed Position:

of FOR CONTRACT AWARD

\* note to supplients: kindly indicate your opposed price paper item. Do not lumpeum your bid