



UNIVERSITY OF THE PHILIPPINES
LOS BANOS
Los Banos, IV-A
VAT Reg. TIN: 000-864-006-00004

Request for Quotation/ Bid Form (Technical Specifications)
OFFICE OF THE VICE CHANCELLOR FOR PLANNING AND DEVELOPMENT

UPLB BAC SECRETARIAT
BY: Jan DATE: 12/13/2023
DEC 18 2023
UPLB-RQ- 12-152-23-I-10am
DEADLINE OF SUBMISSION

UPLB-RQ-

DEADLINE OF
SUBMISSION:

Suppliers Name: _____

Date: December 09, 2023
Fund Code: C0003527 - UPLB 9151038
MOP: Competitive Bidding
Contact No: 049 5762625
Contact Person: Engr. Jan Marc T. Malenab

Please quote your lowest price on the item/s listed below, subject to the General Conditions below.

Note:

- Bidders shall provide correct and accurate information required in this form. All entries must be typewritten or in print and properly accomplished. Do not leave blank entries, put N/A for not applicable.
- Price quotation/s to be denominated in Philippine Peso shall include all taxes, duties, and/ or levies payable.
- Bidders must indicate the BRAND and MODEL NUMBER for equipment and its accessories or peripherals. Evidence shall be in the form of manufacturer's un-amended sale literature, unconditional statement of specification and compliance issued by the manufacturer and sample.
- Quotation through fax/email is acceptable. Winning bidder shall submit original signed RQ before issuance of Purchase order (P.O.).
- Quotations exceeding the Approved Budget for Contract shall be rejected.
- Documentary requirements per Memorandum No. 03 Series of 2017 shall be attached upon submission of the quotation
- Others: _____

ITEM No.	GENERAL NAME OF THE ITEM	REQUIRED SPECIFICATIONS	UNIT OF MEASURE	QTY	ESTIMATED UNIT APPROVED BUDGET OF THE CONTRACT	ESTIMATED TOTAL APPROVED BUDGET OF THE CONTRACT	OFFERED SPECIFICATION <small>Suppliers must state here the detailed technical specifications of their offer against each of the individual parameters of each requirements</small>	QUOTED UNIT PRICE	TOTAL QUOTED PRICE	EVALUATION <small>(Leave this space blank. For BAC/Evaluators only)</small>
1	Digital Insulation Tester 1000V AC	1000V Digital Insulation Tester Measuring range: 4M/40M/400/4000MΩ Accuracy: ±(3%+4) ACV/DCV: 600V(AC/DC) Automatic detection DI(Continuity) 400Ω(Buzzer and ALARM Indicator Rated Current: 1~1.2 mA Safety Standard: IEC61010 CAT. III 600V	set	1	30,000.00	30,000.00				
2	Electrical Panel Board Assembly 1 (Right Wing Panel Board)	Panel Board Housing: from Ga.#16 (base metal thickness) Plain G.I. Sheet. Complete with Door Hinges, Polished Metal Catch and Lock, Pre-painted/Pre-molded, Powder Coated Finish. (Manufacturer's Standard Finish) Main: 100AT, 100AF 3-Pole, 600V, Molded Case Type, Industrial Circuit Breaker, Thermal Magnetic Trip, Noninterchangeable Trip, UL listed for HID, UL listed HACR. Branches: 7 - 40AT, 50AF, 2-Pole, 230V 3 - SPARE All Branch Circuit Breakers are Molded Case and Bolt-on Type, 230V Class, 22kAIC Internal Common Trip, UL listed as SWD rated, UL listed HACR	set	1	16,477.50	16,477.50				
3	Electrical Panel Board Assembly 2 (left wing Panel Board)	Panel Board Housing: from Ga.#16 (base metal thickness) Plain G.I. Sheet. Complete with Door Hinges, Polished Metal Catch and Lock, Pre-painted/Pre-molded, Powder Coated Finish. (Manufacturer's Standard Finish) Main: 100AT, 100AF 3-Pole, 600V, Molded Case Type, Industrial Circuit Breaker, Thermal Magnetic Trip, Noninterchangeable Trip, UL listed for HID, UL listed HACR, "GE" or approved equal. Branches: 8 - 40AT, 50AF, 2-Pole, 230V 1 - 30AT, 50AF, 2-Pole, 230V 1 - SPARE All Branch Circuit Breakers are Molded Case and Bolt-on Type, 230V Class, 22kAIC Internal Common Trip, UL listed as SWD rated, UL listed HACR, "GE" or approved equal	set	1	19,051.50	19,051.50				

4	Electrical Panel Board Assembly 3 (North Wing Panel Board)	Panel Board Housing from Ga.#16 (base metal thickness) Plain G.I. Sheet. Complete with Door Hinges, Polished Metal Catch and Lock, Pre-painted/Pre-molded, Powder Coated Finish, (Manufacturer's Standard Finish) Main: 150AT,225AF 3-Pole, 600V, Molded Case Type, Industrial Circuit Breaker, Thermal Magnetic Trip, Noninterchangeable Trip, UL listed for HID, UL listed HACR, "GE" or approved equal. Branches: 10 - 40AT, 50AF, 2-Pole, 230V 1 - 30AT, 50AF, 2-Pole, 230V 1 - SPARE All Branch Circuit Breakers are Molded Case and Bolt-on Type, 230V Class, 22kAIC Internal Common Trip, UL listed as SWD rated, UL listed HACR, "GE" or approved equal	set	1	31,722.60	31,722.60			
5	Electrical Panel Board Assembly 5 (Center Building Complex Panel Board)	Panel Board Housing from Ga.#16 (base metal thickness) Plain G.I. Sheet. Complete with Door Hinges, Polished Metal Catch and Lock, Pre-painted/Pre-molded, Powder Coated Finish, (Manufacturer's Standard Finish) Main: 200AT,225AF 3-Pole, 600V, Molded Case Type, Industrial Circuit Breaker, Thermal Magnetic Trip, Noninterchangeable Trip, UL listed for HID, UL listed HACR, "GE" or approved equal. Branches: 2 - 40AT, 50AF, 2-Pole, 230V 4 - 30AT, 50AF, 2-Pole, 230V 2 - SPARE All Branch Circuit Breakers are Molded Case and Bolt-on Type, 230V Class, 22kAIC Internal Common Trip, UL listed as SWD rated, UL listed HACR, "GE" or approved equal	set	1	15,229.50	15,229.50			
6	Electrical Panel Board Assembly 5 (North Wing Panel Board)	Panel Board Housing from Ga.#16 (base metal thickness) Plain G.I. Sheet. Complete with Door Hinges, Polished Metal Catch and Lock, Pre-painted/Pre-molded, Powder Coated Finish, (Manufacturer's Standard Finish) Main: 200AT,225AF 3-Pole, 600V, Molded Case Type, Industrial Circuit Breaker, Thermal Magnetic Trip, Noninterchangeable Trip, UL listed for HID, UL listed HACR, "GE" or approved equal. Branches: 13 - 40AT, 50AF, 2-Pole, 230V 3 - SPARE All Branch Circuit Breakers are Molded Case and Bolt-on Type, 230V Class, 22kAIC Internal Common Trip, UL listed as SWD rated, UL listed HACR, "GE" or approved equal		1	33,781.80	33,781.80			
7	Electrical PVC Elbow	110mmø PVC Elbow, Thick wall, 80 Joules Izod impact, 55MPa Tensile strength, PNS 14	pc	4	803.47	3,213.88			
8	Electrical PVC Elbow	75mmø PVC Elbow, Thick wall, 80 Joules Izod impact, 55MPa Tensile strength, PNS 14	pc	5	383.47	1,917.35			
9	Electrical PVC Elbow	50mmø PVC Elbow, Thick wall, 80 Joules Izod impact, 55MPa Tensile strength, PNS 14	pc	15	255.65	3,834.75			
10	Electrical PVC Elbow	32mmø PVC Elbow, Thick wall, 80 Joules Izod impact, 55MPa Tensile strength, PNS 14	pc	17	77.18	1,312.06			
11	Electrical PVC Pipe	110mmø PVC Pipe, 3 meters Trade length, Thick wall, 80 Joules Izod impact, 55MPa Tensile strength, PNS 14	pc	3	1,073.10	3,219.30			
12	Electrical PVC Pipe	75mmø PVC Pipe, 3 meters Trade length, Thick wall, 80 Joules Izod impact, 55MPa Tensile strength, PNS 14	pc	30	658.49	19,754.70			
13	Electrical PVC Pipe	50mmø PVC Pipe, 3 meters Trade length, Thick wall, 80 Joules Izod impact, 55MPa Tensile strength, PNS 14	pc	34	439.00	14,926.00			
14	Electrical PVC Pipe	32mmø PVC Pipe, 3 meters Trade length, Thick wall, 80 Joules Izod impact, 55MPa Tensile strength, PNS 14	pc	17	280.96	4,778.32			
15	Electrical Wire (Black)	250mm ² T.H.H.N-2 Copper, Stranded, 600V, Electrical Wire(Black), UL-listed, branded	m	36	2,265.98	81,575.28			
16	Electrical Wire (Black)	30mm ² T.H.H.N-2 Copper, Stranded, 600V, Electrical Wire (Black), UL-listed, branded	m	300	265.10	79,530.00			
17	Electrical Wire (Black)	60mm ² T.H.H.N-2 Copper, Stranded, 600V, Electrical Wire, UL-listed, branded	m	225	549.55	123,648.75			
18	Electrical Wire (Black)	14mm ² T.H.H.N-2 Copper, Stranded, 600V, Electrical Wire, UL-listed, UL-listed, branded	m	160	130.03	20,804.80			
19	Electrical Wire (Green)	60mm ² T.H.H.N-2 Copper, Stranded, 600V, Electrical Wire(Green), UL-listed, branded	m	12	722.74	8,672.88			
20	Electrical Wire (Green)	30mm ² T.H.H.N-2 Copper, Stranded, 600V, Electrical Wire (Green), UL-listed, branded	m	87	265.10	23,063.70			
21	Electrical Wire (Green)	8.0mm ² T.H.H.N-2 Copper, Stranded, 600V, Electrical Wire (Green), UL-listed, branded	m	100	75.90	7,580.00			
22	Electrical Wire (Green)	22mm ² T.H.H.N-2 Copper, Stranded, 600V, Electrical Wire, UL-listed, branded	m	75	203.62	15,271.50			
23	Electrical Wire (Green)	5.5mm ² T.H.H.N-2 Copper, Stranded, 600V, Electrical Wire, UL-listed, branded	m	54	51.41	2,776.14			

24	Electrical Wire(Black)	100mm ² T.H.H.N-2 Copper, Stranded, 600V, Electrical Wire (Black), UL-listed, branded	m	260	902.16	234,561.60			
25	MAIN DISTRIBUTION PANEL	MDP - Panel Board Housing: from Ga #16 (base metal thickness) Plain G.I. Sheet, Complete with Door Hinges, Polished Metal Catch and Lock, Pre-painted/Pre-molded, Powder Coated Finish, (Manufacturer's Standard Finish) Main: 800AT, 3-Pole, 600V, 70 kAIC @ 220-230V Molded Case Type, Industrial Circuit Breaker, Thermal Magnetic Trip, Noninterchangeable Trip, UL listed for HID, UL listed HACR, BRANDED. Bus Bar Copper Data: 1/2" thk., 1-1/2" width Branches: 2- 125AT, 225AF, 3-Pole, 230V 1- 150AT, 225AF, 3-Pole, 230V 1- 200AT, 225AF, 3-Pole, 230V 2- 100AT, 100AF, 3-Pole, 230V 2- Spare, 100AF, 3-Pole, 230V All Branch Circuit Breakers are Molded Case and Bolt-on Type, 230V Class, 22kAIC Internal Common Trip, UL listed as SWD rated, UL listed HACR, BRANDED	set	1	171,104.05	171,104.05			
26	Metal Locknut & Bushing	75mm Ø Metal Locknut & Bushing	set	3	120.00	360.00			
27	Metal Locknut & Bushing	50mm Ø Metal Locknut & Bushing	set	8	80.00	640.00			
28	Metal Locknut & Bushing	32mm Ø Metal Locknut & Bushing	set	3	50.00	150.00			
29	PVC Adaptor	75mm Ø PVC Adaptor, 80 Joules Izod Impact, 55MPa Tensile Strength,	pc	3	383.47	1,150.41			
30	PVC Adaptor	50mm Ø PVC Adaptor, 80 Joules Izod Impact, 55MPa Tensile Strength,	pc	8	255.65	2,045.20			
31	PVC Adaptor	32mm Ø PVC Adaptor, 80 Joules Izod Impact, 55MPa Tensile Strength,	pc	3	77.18	231.54			
32	PVC Solvent Cement	ASTM D2564-12 PVC Pipe Solvent Cement, 400 cc/can	pc	5	178.57	892.85			
TOTAL ABC						973,285.06			
						TOTAL QUOTED AMOUNT IN WORDS:			

Reviewed and Checked By:


DONAT REY D. CAMUS
BAC TWG

Please quote at your government price (including VAT) and state that the time within which you can make delivery. It will be appreciated if we can have your quotation in the office as soon as possible on or before the deadline stated herein.


ENGR. JAN MARC T. MALENAB
Buyer

TERMS AND CONDITIONS:

- Price quotation/s shall be valid for a period of at least (30) calendar days from the date of submission.
- In order to assure that manufacturing defects shall be corrected by supplier, a warranty security shall be required from the contract awardee for a minimum period of three (3) months, in the case of EXPENDABLE SUPPLIES, or a minimum of one (1) year warranty and two (2) to three (3) years extended warranty (if applicable) in the case of NON-EXPENDABLE SUPPLIES after acceptance by End-user of the delivered supplies.
- Delivery period within _____ calendar days.
- Award of contract shall be made to the lowest quotation which complies with the technical specifications, and other terms and condition stated herein
- UPLB reserves the right to reject any or all offers as may be considered most advantageous to the University.
- Any interlineations, erasure, or overwriting shall be valid only if they are signed or Initiated by you or any of your duly authorized representatives.

Requirements for Suppliers (GPPB Resolution No. 21-2017)

REQUIREMENTS	Shopping (Section 52)	Negotiated Procurement- Small Value Procurement (Section 53.9)	Negotiated Procurement- Lease of Real Property or Venue (Section 53.10)	Negotiated Procurement- Scientific, Scholarly or Artistic Work, Exclusive Technology and Media Services (Section 53.6)	Negotiated Procurement- Emergency (Section 53.2)
1 Mayor's/Business Permit	/	/	/	/	/
2 PhilGEPS Registration Number	/	/	/	/	/
3 Professional license/ CV (consulting services)	/	/	/	/	/
4 PCAB License (for Infrastructure)	/	/	/	/	/
5 Income / Business tax returns (except for government agencies as lessor)		FOR ABC'S ABOVE 500K	/	/	FOR ABC'S ABOVE 50K
6 Omnibus Sworn Statement		FOR ABC'S ABOVE 50K			FOR ABC'S ABOVE 500K
7 NFCC for Infrastructure with ABC above Ph500k		/			FOR ABC'S ABOVE 50K

After having carefully read and accepted your General Conditions, I/We quote you on the Item at prices noted above.

Name of the Company: _____

Address: _____

Tel. No. : _____

Fax No. : _____

Signature over Printed Name of Representative: _____

Email Address: _____

Position: _____

Date: _____