



UNIVERSITY OF THE PHILIPPINES
LOS BANOS
Los Banos, IV-A
VAT Reg. TIN: 000-864-006-00004

Request for Quotation/ Bid Form (Technical Specifications)
Institute of Crop Science

UPLB BAC SECRETARIAT
BY: jm DATE: 01/22/2024
JAN 29 2024
UPLB-RQ-1-006-24-I-10am
DEADLINE OF SUBMISSION

UPLB-RQ-

DEADLINE OF
SUBMISSION:

Suppliers Name: _____

Date: November 06, 2023
Fund Code: N9-301-21
MOP: Competitive Bidding
Contact No: 9310228611
Contact Person: Jayson D. Palleria
palleria01@gmail.com


Please quote your lowest price on the item/s listed below, subject to the General Conditions below.


With PCAB License

- Note:
- Bidders shall provide correct and accurate information required in this form. All entries must be typewritten or in print and properly accomplished. Do not leave blank entries, put N/A for not applicable.
 - Price quotation/s to be denominated in Philippine Peso shall include all taxes, duties, and/ or levies payable.
 - Bidders must indicate the BRAND and MODEL NUMBER for equipment and its accessories or peripherals. Evidence shall be in the form of manufacturer's un-amended sale literature, unconditional statement of specification and compliance issued by the manufacturer and sample.
 - Quotation through fax/email is acceptable. Winning bidder shall submit original signed RQ before issuance of Purchase order (P.O.).
 - Quotations exceeding the Approved Budget for Contract shall be rejected.
 - Documentary requirements per Memorandum No. 03 Series of 2017 shall be attached upon submission of the quotation
 - Others: _____

ITEM No.	GENERAL NAME OF THE ITEM	DESCRIPTION	UNIT OF MEASURE	QTY	ESTIMATED UNIT APPROVED BUDGET OF THE CONTRACT	ESTIMATED TOTAL APPROVED BUDGET OF THE CONTRACT	OFFERED SPECIFICATION Suppliers must state here the detailed technical specifications of their offer against each of the individual parameters of each requirements	QUOTED UNIT PRICE	TOTAL QUOTED PRICE	EVALUATION (Leave this space blank. For BAC/Evaluators only)
1	Aircon Equipment	Brand new 2.0 HP FULL DC Inverter Type Wall Mounted Split type Air-Conditioning unit with rated Cooling Capacity 18,000 (3,960-19,440) Watts, 230 Volts, 60Hz, 1-Phase, Rated Current 7.0 max Amps, Liquid Side(1/4" O.D) Gas Side(1/2"O.D) Refrigerant R-32 Wireless Remote Control.	UN	1	92,743.55	92,743.55				
Scope of Work										
2	Cost of Labor and Materials for Installation of one(1) A/C Unit	A) Layout and Installation of Fabricated Angle Bar 3/16" x 1 1/2" thickness, pre-painted primer epoxy(gray for ACCU). B) Mounting and Installation of Air Conditioning units FCU over ceiling and ACCU with Rubber Pad Support C) Chipping and Plastering of Concrete, Etc. D) Layout and Installation of Drainage Pipeline using PVC 1/2" Diamater (Eslon Blue) and flushing of old drainage line E) Layout and Installation of PVC Electrical Connection with Power and transmission wiring from FCU to ACCU using F) Layout and Installation of Electrical Wiring 5.5mm ² and Liquid Tight Flexible Conduit with Connector from ACCU to 30 amp. Circuit Breaker NEMA 3r enclosure (1 meter from ACCU) G) Layout and Installation of Hard Drawn Copper pipe 1/2" O.D and 1/4" O.D. Type -L with rubber insulation 1/4" thickness from FCU to ACCU including Vinyl tape Insulation. H) Leak Testing and Correction, System Flusing and Vacuuming I) Installation of metal cladding of refrigerant pipe set from ACCU to FCU using galvanize iron 0.5mm thk. As per drawing 1" X 3" x 3" sizes, pre-painted (same as wall painted.) J) Refrigerant Charing and start up with commissioning K) Attach Certificate of Warranty and FREE 1 General Cleaning before end of 1 year warranty.								
	A. Copper Pipe and Fitting with Insulations	Copper Pipe 1/2" O.D. x 0.89mm THK type - L hard drawn, 30 ft Copper Pipe 1/4" O.D. x 0.61mm THK type -L hard drawn, 30 ft Copper Elbow 1/2" I.D. x 90° Long Radius, 4 pcs. Copper Elbow 1/4" I.D. x 90° Long Radius, 4pcs. Flat silver rod 18", 4 pcs. Elastomic Rubber Insulation 1/2" I.D. x 3/4" THK x 6' Elastomic Rubber Insulation 1/2" I.D. x 1/2" THK x 6' Polyethelene Vinyl Tape Insulation 4" x 50 meters, 3 rolls								
	B. Electrical Work for ACCU to FCU, control wirings, condensate drain	Circuit Breaker 30 Amps. 2 pole, Bolt on Type, NEMA 3R THHN Stranded Wire #3.5mm ² , 45 mtrs THHN Stranded Wire #5.5mm ² , 5 mtrs PVC Pipe 1/2" dia x 10' (Neltex), length 3 PVC Long Elbow 1/2" x 90°(Neltex), 4 pcs Liquid Tight Electrical Flexible Hose 1/2" dia. (soft), 2 mtrs Liquid Tight Straight Connector 1/2", 2 pcs PVC Pipe 1/2" dia x 10' (Eslon Blue), length 3 PVC Short Elbow 1/2" dia x 90° (Eslon Blue), 3 pcs								

C. Steel Frame and Metal Cladding Support for ACCU to FCU	Angle Bar 3/16" x 1 1/2" x 20' feet, length 1										
	welding rod, 1 kg										
	Bolt & Nut with flat/lock washer 5/16" x 2" long, 4 pcs										
	Plastic tox with metal screw(6mm), 30pcs										
	Expansion Shield 1/4" dia x 2" long galvanized bolt screw, 6 pcs										
	G.I Plain Sheet 3 x 8 x 0.5mm (for cladding materials), 1 sheet										
D. Refrigerant System Flushing, Leak Testing, Vacuuming, Charing	Refrigerant R-32, 2kg										
E. Other Contingency to Complete the Installation (for 2 units)	Mapp Gas, Welding, Brazing, Cutting, Painting, Bending and Consumable Materials, etc.										
TOTAL ABC										92,743.55	
TOTAL QUOTED AMOUNT IN WORDS:											

Reviewed and Checked By:  BAC TWG


JAYSON D. PALLERA
BUYER/ END-USER

Please quote at your government price (including VAT) and state that the time within which you can make delivery. It will be appreciated if we can have your quotation in the office as soon as possible on or before the deadline stated herein.

TERMS AND CONDITIONS:

- Price quotation/s shall be valid for a period of at least (30) calendar days from the date of submission.
- In order to assure that manufacturing defects shall be corrected by supplier, a warranty security shall be required from the contract awardee for a minimum period of three (3) months, in the case of EXPENDABLE SUPPLIES, or a minimum of one (1) year
- Delivery period within **30** calendar days.
- Award of contract shall be made to the lowest quotation which complies with the technical specifications, and other terms and condition stated herein
- UPLB reserves the right to reject any or all offers as may be considered most advantageous to the University.
- Any interlineations, erasure, or overwriting shall be valid only if they are signed or initiated by you or any of your duly authorized representative/s.

Requirements for Suppliers (GPPB Resolution No. 21-2017)

REQUIREMENTS	Shopping (Section 52)	Negotiated Procurement- Small Value Procurement (Section 53.9)	Negotiated Procurement- Lease of Real Property or Venue (Section 53.10)	Negotiated Procurement- Scientific, Scholarly or Artistic Work, Exclusive Technology and Media Services (Section 53.6)	Negotiated Procurement- Emergency (Section 53.2)
1 Mayor's/Business Permit	/	/	/	/	/
2 PhilGEPS Registration Number	/	/	/	/	/
3 Professional license/ CV (consulting services)		/		/	
4 PCAB License (for Infrastructure)		/			
5 Income / Business tax returns (except for government agencies as lessor)		FOR ABC'S ABOVE	/	/	FOR ABC'S
6 Omnibus Sworn Statement		FOR ABC'S ABOVE			FOR ABC'S
7 NFCC for Infrastructure with ABC above Ph500k		/			FOR ABC'S ABOVE 50K

After having carefully read and accepted your General Conditions, I/We quote you on the Item at prices noted above.

Name of the Company: _____ Tel. No. : _____
Address: _____ Fax No. : _____
Signature over Printed Name of _____ Email Address: _____
Position: _____ Date: _____